

Victor Products Ltd
Unit 3A, Tyne Dock East Side
Port of Tyne,
South Shields,
Tyne and Wear
NE33 5SQ
United Kingdom
Tel : +44(0)191 2808000
Fax : +44(0)191 2808080



**Making Hazardous
Environments Work**

**TYPE 3RPCA 500AMP 3300VOLTS MAX. RESTRAINED
FLAMEPROOF PLUG COUPLER**

Certification number Baseefa02ATEX0133 I M2 EExd I

For India only – The Test Plug has been designed in accordance with IS/IEC 60079-0:2004 and IS/IEC 60079-1:2007. Test report number CIMFR/TC/C/H334.




NAMEPLATE DETAIL

General

These Restrained Plug Coupling units Type are designed in accordance with EN50014: 1997 and EN50018: 2000. They can be associated with the following Group I certified connectors for flameproof equipment.

Type 30PA
Type 30P

Certificate Baseefa02ATEX0132U
Certificate HSE(M)90B5040U.



Installation – all.

1. Suitably qualified personnel in accordance with established codes of practice must carry out installation, maintenance, and inspection.
2. Ensure that the rated voltage and current are compatible with the power supply and load requirements. To assist in using circuits with different voltages, the insulator can be rotated through 180°. This rotation prevents the insertion of a plug into the coupler when voltage restrictions are applied.
3. Ensure that when the plugs are connected for use, with their mating approved couplers, that they are fully engaged.

Maintenance and Inspection

It should be noted that the original manufacturer must supply all components that are to be replaced. Failure to use such components invalidates the certification and approval and may make the apparatus dangerous. NO modifications should be made to the apparatus without the knowledge and approval of the manufacturer. If in doubt, refer to the manufacturer. A copy of the Spare Parts List is available from Victor Products Ltd.

Before re-assembly ensure that all flameproof paths are visually inspected and dimensionally checked for any abnormality.

HEALTH AND SAFETY AT WORK etc. ACT 1974

In the United Kingdom all equipment must be installed, operated and disposed of (as required) within the legislative requirements of the Health and Safety at Work etc. Act 1974. Leaflet No. HSS L1 refers to the Company's obligation and is available on request.

It is the responsibility of the user to select, install, operate and maintain the equipment in accordance with the relevant legislation and appropriate code of practice.



Prices and design are subject to alteration without notice. All products are sold subject to our conditions of sale, copies of which are available on request.

We reserve the right to change characteristics of our products. All data is for guidance only

**INTENTIONALLY
BLANK.**

Declaration of conformity

Déclaration De Conformité
Konformitätserklärung



Victor Products Ltd
Unit 3A, Tyne Dock East Side
Port of Tyne,
South Shields,
Tyne and Wear
NE33 5SQ
United Kingdom

TYPE 3RPCA 500AMP 3300VOLTS MAX. RESTRAINED FLAMEPROOF PLUG COUPLER


Certification number Baseefa02ATEX0133 I M2 EExd I

Victor Products Ltd

Hereby declare our sole responsibility that the product which is the subject of this declaration is in conformity with the following standards or normative documents.

Erklären in alleiniger Verantwortung, daß das Product auf das sich diese Erklärung bezieht, mit der/den folgenden Norm(en) oder normativen Dokumenten Ubereinstimmt.

Déclarons de notre seule responsabilité, que le produit auquel cette déclaration se rapporte, est conforme aux norme(s) ou aux documents normatifs suivants.

Number and date of standard Nr. Sowie Ausgabedatum der Norm No. Ainsi que date d'émission des normes.	Directive description Bestimmungen der Richtlinie Prescription de la directive
EN 50014 (1998) EN 50018 (2000) This equipment has been reviewed against the requirements of EN60079-0: 2018 and EN60079-1: 2014, in respect of the differences from the standards to which this certificate was issued; none of these differences affect this equipment. Dieses Gerät wurde hinsichtlich der Unterschiede zu den Standards, für die dieses Zertifikat ausgestellt wurde, mit den Anforderungen von EN60079-0: 2018 und EN60079-1: 2014 verglichen. Keiner dieser Unterschiede wirkt sich auf dieses Gerät aus. Cet équipement a été passé en revue contre les conditions d'EN60079-0 : 2018 et EN60079-1 : 2014, en ce qui concerne les différences des normes auxquelles ce certificat a été délivré ; aucune de ces différences n'affecte cet équipement.	Equipment and protective systems intended for use in potentially explosive atmospheres. This Attestation is valid for directive 2014/34/EU. Geräte und Schutzsysteme zur bestimmungsgemäßen Verwendung in explosionsgefährdeten Bereichen. Diese Bescheinigung gilt für die Richtlinie 2014/34 /EU. Appareils et systèmes de protection destinés à être utilisés en atmosphères explosibles. Cette Attestation est valable pour la directive 2014/34 /UE.
EN50082 (1992) EN55015 (1993) EN 60555-2 (1987)	89/336 EEC: Electromagnetic Compatibility 89/336 EWG: Elektromagnetische Verträglichkeit 89/336 CEE: Compatibilité électromagnétique
Notified Body: CSA Group Netherlands B.V. Notified Body No. 2813	 P. Devlin Operations Manager January 2024

SERIAL NUMBER